

STATE OF NORTH CAROLINA

NC EDUCATION LOTTERY



IMPORTANT ADDENDUM

November 10, 2009

THIS BID ADDENDUM DOES NOT HAVE TO BE RETURNED:

BID NUMBER: LC-000022
ADDENDUM NUMBER: 3
PURCHASER: Michele Goff

COMMODITY: Fire Suppression System and Related Services
USING AGENCY: North Carolina Education Lottery
OPENING DATE/TIME: November 20, 2009, 4:00 pm EST

QUESTIONS AND ANSWERS

1.) Need name of Companys currently maintaining Fire Alarm Systems at both locations.

NCEL HQ - Edwards Electronics - 919-359-2239

Greensboro – Information not received for this posting – to be included with next addendum.

2.) Need name of Companys currently maintaining HVAC Systems at both locations.

NCEL HQ - Piedmont Air Conditioning - 919-851-5800

Greensboro - Koury Corporation - 336-299-9200

3.) Need name of Electricans being used to maintain Electrical Systems at both locations.

NCEL HQ - Hi-Lite Electric - 919-422-7281
Ham Electric - 919-272-8390

Greensboro - Propst and Son - 919-876-5885
Koury Corporation - 336-299-9200

4.) Can ceiling tiles be installed in Clean Agent spaces that are currenty open to the plenum ceiling above.

Ceiling tiles can be installed where there are plenum returns in all rooms, except in the LAN room in Greensboro.

5.) Are all HVAC supplies and returns in Clean Agent spaces dampered?

HVAC supplies are currently dampered.