

# STATE OF NORTH CAROLINA

## NC EDUCATION LOTTERY



### IMPORTANT ADDENDUM

November 12, 2009

#### **THIS BID ADDENDUM DOES NOT HAVE TO BE RETURNED:**

BID NUMBER: LC-000022  
ADDENDUM NUMBER: 4  
PURCHASER: Michele Goff

COMMODITY: Fire Suppression System and Related Services  
USING AGENCY: North Carolina Education Lottery  
OPENING DATE/TIME: November 20, 2009, 4:00 pm EST

#### **QUESTIONS AND ANSWERS**

**1.) Need name of Companys currently maintaining Fire Alarm Systems at both locations.**

Greensboro - Simplex - 336-841-8550 (This information was not included on Addendum #3. Please refer to Addendum #3 for complete list).

**2.) Are you going to require EPO (power shut down ) to be tied to Suppression Panels. If so are there manual switches in any of the 3 rooms?**

No.

**3.) Please provide names of contractors familiar with work in the building for the following trades: electrical and alarm systems.**

Please refer to Item #1 (above) and Addendum #3.

**4.) Does the Data Center Room 214 need preaction system coverage below raised floor?**

No.

**5.) Please confirm that preaction systems need to be double interlock electric/pneumatic.**

Please provide more information.

**6.) Please advise if preaction risers can be field assembled or prepackaged systems.**

Either one is fine.